



The Airwave is a Non Touch switch ideal for automatic door activation or clean room access control where hygiene is of the utmost importance.

Functional data:

- Elegant non contact switch
- Well suited for clean room/sterile areas access, for disabled activation of automatic doors or for equipment control in the pharmaceutical or chemical industry.
- Detection not dependent on the optical parameters of an object as is the case with other switch technologies.
- Switch activation possible with gloved hand
- Possibility to use several sensors in close proximity
- Adjustable detection field of between 0 to 10 cm
- Acoustic signal during detection (May also be switched off)
- Volume control of acoustic signal possible
- LED indicator during detection and standby mode making the sensor more visible to visually impaired users (11 different programs)
- Universal relay output (one C type contact)
- Regulation of relay hold time by potentiometer (0,6s up to 50s)



ST-ARV-010



ST-ARV-020

Installation instructions:

- 1. Turn off power supply**
2. Unscrew the front graphic panel using hexagonal 2mm key.
3. Screw back part of the case to the mounting point (e.g., a wall).
4. Connect wires to relay contacts. CO-NO contacts are shorted during detection, CO-NC contacts are shorted when there is no detection or when there is no power supply. (CO = Common, NO = Normally open, NC = Normally closed).
5. Connect power supply wires “+” and “-”. You can achieve better stability and bigger sensing field when “-” wire is grounded.
- 6. Turn on power supply**
7. Using the potentiometers set the volume of the acoustic signal (VOL), the sensitivity (SENS), and the relay time (TIME).

IMPORTANT NOTICE

If problems appear with self activation please turn down the sensitivity (using SENS potentiometer). Self activation may be caused by high electromagnetic noise in some environments.

8. Using pushbutton set up LED program (see technical data table bellow)
9. Put wires far from the capacitive electrode.
10. Screw the front graphic panel (do not screw it down hard).
11. Test your settings by waving your hand in front of the sensor several times

Technical data:

Type	ST-ARV-010,20
Detection method	Capacitive
Range	1 to 10cm
Power supply	12 to 24V AC DC +/-10%
Power consumption (external power)	max <55mA, typically about 15mA
Power consumption (battery)	<110uA
Output	C-type relay
Output operating time	Regulated by potentiometer from 0.6s to 50s
Response time	When powered externally: 50ms When powered from battery: 100ms
Sensitivity adjustment	Potentiometer 10% to 100%
Acoustic signal loudness	Potentiometer from 0% to 100%
LED indication	Detection: LED is ON for 1s Standby: you can chose one from 11 programs by pushbutton: 1. 0.50s ON, 0.50s OFF... (blinking 1Hz) 2. 0.25s ON, 0.25s OFF... (blinking 2Hz) 3. 0.10s ON, 0.10s OFF... (blinking 5Hz) 4. 0.50s ON, 0.05s OFF... (blinking 10Hz) 5. 0.10s ON, 0.50s OFF... (one long flash and pause) 6. 0.05s ON, 0.50s OFF... (one short flash and pause) 7. 0.10s ON, 0.10s OFF, 0.10s ON, 0.50s OFF... (two long flashes and pause) 8. 0.05s ON, 0.10s OFF, 0.05s ON, 0.50s OFF... (two short flashes and pause) 9. 0.10s ON, 0.10s OFF, 0.10s ON, 0.10s OFF, 0.10s ON, 0.50s OFF... (three long flashes and pause) 10. 0.05s ON, 0.10s OFF, 0.05s ON, 0.10s OFF, 0.05s ON, 0.50s OFF... (three short flashes and pause) 11. OFF
Operating temperature	-20C to +55C
Dimensions and weight	ST-ARV-10: 82 x 82 x 30mm, 95g net, 140g gross ST-ARV-20: 82 x 102 x 25mm, 110g net, 160g gross
Equipment	<ul style="list-style-type: none">• Sensor• Hexagonal 2mm key• Instruction



Senstronix

Grunwaldzka 235
85-438 Bydgoszcz
Poland

Tel: +48 52-349-04-26

Fax: +48 52-360-42-18

www.senstronix.com

info@senstronix.com